

7835.0800 SCHEDULE E.

Schedule E must contain the utility's safety standards, required operating procedures for interconnected operations, and the functions to be performed by any control and protective apparatus. These standards and procedures must not be more restrictive than the interconnection guidelines listed in parts 7835.4800 to 7835.5800. The utility may include in schedule E suggested types of equipment to perform the specified functions. No standard or procedure may be established to discourage cogeneration or small power production.

Statutory Authority: *MS s 216A.05; 216B.08; 216B.164*

History: *9 SR 993*

Published Electronically: *February 28, 2000*